## GOOD DIESEL TANK DETAILS







1. Stainless-steel bushings insulate copperalloy (brass, bronze) fittings from tank. 2. Non-hydroscopic material (preferably adhered to tank itself) isolates tank from wood. 3. Install inspection plates into every baffled chamber. 4. Leave at least a 1/4-inch air gap between bottom of tank and its shelf.

